



PRODUCT NUMBER: 2091903

ELECTROSOFT CLASS 00

For electrical work with a maximum voltage of 500 volts. Must be used with a leather overglove.

Overview	<p>Reference Number 2091903</p> <p>Product Type Gloves</p> <p>Range Electrical Protection</p> <p>Line Latex</p> <p>Brand Sperian</p> <p>Brand formerly known as ELECTROSOFT</p> <p>Industry</p> <div><div></div> Energy or Electricity<div></div> Maintenance<div></div> Telecoms</div> <p>Product Use For electrical work with a maximum voltage of 500 volts. Must be used with a leather overglove.</p>
----------	--

Features & Benefits

Feature

Beige natural latex insulating glove
Cut edge
Category AZC

Benefit

COMFORT

Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

RESISTANCE

Its natural latex base offers high dielectric characteristics.

Its thickness (0.5 mm) ensures good dexterity while offering protection up to 500 volts of use.

SAFETY

It must be used with a leather overglove.

Technical Description

Description

CE CATEGORY : III Irreversible risks

In accordance with standards :

EN 60903-2003

CEI 903-2002

CHARACTERISTICS :

Beige natural latex insulating glove

Category AZCv

Product Technology

Dipped Gloves

Glove/liner color

Beige

Coating Type

Latex

Length

36 cm

Thickness

0.5 mm

Harmlessness

In conformity with the European standards

Dexterity

Class 00

Sizes

7 to 11

Packaging Label

Tagging


CE SPERIAN

2091903 XX

EN 60903-2003

CEI 903-2002

Certifications

 E.C. Declaration of Conformity

EC Category PPE
3

Quality Assurance
ISO 9001 / 2000

EC Certificate Number
0

EC Attestation
EC Attestation

EC Attestation Number
0077/016/078/03/94/0001 EXT 01/06/06

Photos & Images

We're sorry, there are no images available at this time.

Additional Information

User Manual
UI 106

User Information Sheet
106

Maintenance

Life Cycle
Gloves that are used frequently should be tested at intervals less than 6 month.
Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.
Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information
Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).
Do not compact or fold.
Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation.
Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity



[View other region sites](#)

© 2011 Honeywell International Inc.



E.C. Declaration of Conformity

The manufacturer or its legal representative supplier in the European Community:
Honeywell Safety Europe

Declares that the Personal Protective Equipment described here after conforms to the provisions of the European Council Directive 89/686/CEE:

Designation: ELECTROSOFT CLASS 00

Reference: 2091903

Standard(s): EN 60903

This PPE is the object of the below EC examination certificate n°:
0

Delivered by:

APAVE parisienne
13 - 17 rue Salneuve
75854
PARIS CEDEX 17
France

Drawn up in Roissy, on the 29/03/2013

By: Carlo Granata

Division: Gloves



ZI Paris Nord II 33, rue des Vanesses BP 50288 95958 Roissy CDG France

Tel: +33 (0) 49 90 79 79 Fax: +33 (0)1 49 90 79 80

www.honeywellsafety.com