



**PRODUCT NUMBER: 2091912**  
**ELECTROSOFT CLASS 1**

For electrical work with a maximal voltage of 7500 volts. To be used with leather protectors for mechanical protection.

**Honeywell**

## Overview

**Reference Number**

2091912

**Product Type**

Gloves

**Range**

Electrical Protection

**Line**

Latex

**Brand**

Honeywell

**Brand formerly known as**

ELECTROSOFT

**Industry**

- Energy or Electricity
- Maintenance
- Telecoms
- Transportation
- Utilities

**Product Use**

For electrical work with a maximal voltage of 7500 volts. To be used with leather protectors for mechanical protection.

## Features & Benefits

**Feature**

Beige natural latex insulating glove

Cut edge

Category RC

**Benefit**

COMFORT

Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

**RESISTANCE**

The natural latex base offers high dielectric characteristics.

Its two-toned composition, with its beige interior/black exterior, indicates wear on the whole of the glove.

Its thickness provides good dexterity while offering protection up to 7,500 volts.

**SAFETY**

To be used with leather protectors for mechanical protection.

## Technical Description

**Description**

CE CATEGORY : III Irreversible risks

In accordance with standards :

EN 60903-2003

CEI 903-2002

**CHARACTERISTICS :**

Beige natural latex insulating glove

Category RC

**Product Technology**

Dipped Gloves

**Glove/liner color**

Beige

**Coating Type**

Latex

**Length**

36 cm

**Thickness**

1.5 mm

**Harmlessness**

In conformity with the European standards

**Sizes**

8 to 11

## Packaging Label

**Tagging**

CE HONEYWELL

2091912 XX

EN 60903-2003

CEI 903-2002

## Certifications

**E.C. Declaration of Conformity**

**EC Category PPE**

3

**Quality Assurance**

ISO 9001 / 2000

**EC Certificate Number**

7007

**EC Attestation**

EC Attestation

**EC Attestation Number**

7007

## Additional Information

**User Information Sheet**

On the polybag

## Maintenance

### Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

### Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

### Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity