



# PRODUCT NUMBER: 2091931 **ELECTROSOFT CLASS 3**

Handling of high voltage to 26 500 volts. To be used with leather protectors for mechanical protection.

Honeywell

# **Overview**

## **Reference Number**

2091931

## **Product Type**

Gloves

#### Range

**Electrical Protection** 

#### Line

Latex

#### **Brand**

Honeywell

# Brand formerly known as

**ELECTROSOFT** 

#### Industry

• Energy or Electricity

Maintenance

Telecoms

#### **Product Use**

Handling of high voltage to 26 500 volts. To be used with leather protectors for mechanical protection.

# **Features & Benefits**

# **Feature**

Beige natural latex insulating glove Cut edge

Category RC

#### **Benefit**

COMFORT

Its anatomical shape and lightly powdered interior make it easier to slip the glove on and off.

# RESISTANCE

Its natural latex base offers high dielectric characteristics. Its thickness (2.9 mm) ensures good dexterity while offering protection up to 26,500 volts of use.

SAFETY

Utilities

## ELECTROSOFT CLASS 3 - 2091931

To be used with leather protectors for mechanical protection.

# **Technical Description**

# Description

CE CATEGORY : III Irreversible risks In accordance with standards :

EN 60903-2003 CEI 903-2002

## CHARACTERISTICS:

Beige natural latex insulating glove

Category RC Cut edge

## **Product Technology**

Dipped Gloves

## Glove/liner color

Beige

# **Coating Type**

Latex

# Length

36 cm

# Thickness

2.9 mm

#### Harmlessness

In conformity with the European standards

# Dexterity

Class 3

#### Sizes

9 to 11

# Packaging Label

# **Tagging**

CE HONEYWELL 2091931 XX EN 60903-2003 CEI 903-2002

# **Certifications**

E.C. Declaration of Conformity

# **EC Category PPE**

3

# **Quality Assurance**

ISO 9001 / 2000

#### **EC Certificate Number**

7010

# **EC** Attestation

**EC** Attestation

# **EC Attestation Number**

7010

# **Additional Information**

## **User Information Sheet**

On the polybag

# **Maintenance**

## Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months

Gloves held in stock should be retested at intervals not exceeding 12 months.

#### **Storage Information**

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

#### **Care Instructions**

Inpsection: Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

Precautions: Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning: use water and soap. Dry below 65°C with ambient humidity

© Honeywell International Inc.