



PRODUCT NUMBER: 2092012
ELECTROSOFT COMPOSITE
Class 00

For electrical work with a maximum voltage of 500 volts.
 Can be used without overglove.

Honeywell

Overview

Reference Number

2092012

Product Type

Gloves

Range

Electrical Protection

Line

Composite

Brand

Honeywell

Brand formerly known as

ELECTROSOFT

Industry

• Administration • Energy or Electricity • Maintenance • Telecoms • Utilities

Product Use

For electrical work with a maximum voltage of 500 volts. Can be used without overglove.

Features & Benefits

Feature

Natural latex insulating glove on cotton base

Outside in orange polychloroprene

RC Category, with Mechanical protection

Benefit

COMFORT

Its dielectric natural latex composition on flocked interior base makes it very comfortable.

Product appreciated for its long last and precision.

Its patterned finish gives it a highly appreciated grip in damp conditions.

RESISTANCE

The outer orange elastomer layer provides excellent mechanical resistance.
Its anatomical shape makes flexing easier while ensuring a high level of protection.

SAFETY

It can be used without a leather overglove as it has been combined with a mechanically more resistant elastomer.

Technical Description

Description

CE CATEGORY : III Irreversible risks

In accordance with standards :

EN 60903-2003

CEI 903-2002

CHARACTERISTICS :

Natural latex insulating glove on cotton base

Outside in orange polychloroprene

Class 00

RC Category, with Mechanical protection

Product Technology

Dipped Gloves

Glove/liner color

Orange

Coating Type

Latex, cotton and polychloroprene

Length

36 cm

Thickness

1,8 mm

Harmlessness

In conformity with European standards

Sizes

7 to 11

Packaging Label

Tagging

CE HONEYWELL

2092012 XX

EN 60903-2003

CEI 903-2002

Certifications

E.C. Declaration of Conformity

EC Category PPE

3

EC Certificate Number

7015

EC Attestation

EC Attestation

EC Attestation Number

7015

Additional Information

User Information Sheet

On the polybag

Maintenance

Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity.