



+  [View More](#)

PRODUCT NUMBER: 2092014

# ELECTROSOFT COMPOSITE Class 0

For electrical work with a maximum voltage of 1000 volts. Can be used without leather glove.

Overview

Reference Number

2092014

Product Type

Gloves

Range

Electrical Protection

Line

Composite

Brand

Sperian

Brand formerly known as

ELECTROSOFT

Industry

- Administration

Product Use

For electrical work with a maximum voltage of 1000 volts. Can be used without leather glove.

## Features &amp; Benefits

**Feature**

Insulating glove for electrical work  
 External layer in orange polychloroprene  
 Chlorinated inside  
 Category RC, with mechanical protection

**Benefit****COMFORT**

Its dielectric natural latex composition on chlorinated interior base makes it very comfortable.  
 Product appreciated for its long life and precision.  
 Its patterned finish gives it a highly appreciated grip in damp conditions.

**RESISTANCE**

The outer orange elastomer layer provides excellent mechanical resistance.  
 Its anatomical shape makes flexing easier while ensuring a high level of protection.

**SAFETY**

It can be used without a leather overglove as it has been combined with a mechanically more resistant elastomer.

## Technical Description

**Description**

CE CATEGORY : III Irreversible risks  
 In accordance with standards :  
 EN 60903-2003  
 CEI 903-2002

**CHARACTERISTICS :**

Insulating glove for electrical work  
 External layer in orange polychloroprene  
 Chlorinated inside  
 Category RC, with mechanical protection

**Product Technology**

Dipped Gloves

**Glove/liner color**

Orange

**Coating Type**

Latex and polychloroprene

**Length**

36 cm

**Thickness**

2 mm

**Harmlessness**

In conformity with European standards

**Dexterity**

Class 0

**Sizes**

8 to 11

**Packaging Label**

### Tagging

CE SPERIAN  
2092014 XX  
EN 60903-2003  
CEI 903-2002

## Certifications

### E.C. Declaration of Conformity

#### EC Category PPE

3

#### EC Attestation

 EC Attestation

#### EC Attestation Number

0077/016/078/06/06/0001 EXT 01/05/08

## Photos & Images

We're sorry, there are no images available at this time.

## Additional Information

### User Manual

UI 106

### User Information Sheet

106

## Maintenance

### Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 months.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

### Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

### Care Instructions

**Inspection** : Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

**Precautions** : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

**Cleaning** : use water and soap. Dry below 65°C with ambient humidity.

© Honeywell International Inc.