



+ [View More](#)

PRODUCT NUMBER: 2091911

ELECTROSOFT CLASS 1

For electrical work with a maximal voltage of 7500 volts. Must be used with a leather overglove.

Overview

Reference Number
2091911

Product Type
Gloves

Range
Electrical Protection

Line
Latex

Brand
Sperian

Brand formerly known as
ELECTROSOFT

Industry

- Energy or Electricity
- Maintenance
- Telecoms

Product Use
For electrical work with a maximal voltage of 7500 volts. Must be used with a leather overglove.

Features & Benefits**Feature**

Beige natural latex insulating glove
Cut edge
Category RC

Benefit**COMFORT**

Its ergonomic design combined with a lightly powdered interior increases the comfort by providing additional softness and allows the glove to be put on and taken off very easily.

RESISTANCE

The natural latex base offers high dielectric characteristics.
Its thickness (1.5mm) provides good dexterity while offering protection up to 7,500 volts.

SAFETY

His length protects a large part of the forearm.
It must be used with a leather overglove.

Technical Description**Description**

CE CATEGORY : III Irreversible risks
In accordance with standards :
EN 60903-2003
CEI 903-2002

CHARACTERISTICS :

Beige natural latex insulating glove
Cut edge
Category RC

Product Technology

Dipped Gloves

Glove/liner color

Beige

Coating Type

Latex

Length

41 cm

Thickness

1.5 mm

Harmlessness

In conformity with the European standards

Dexterity

Class 1

Sizes

8 à 11

Packaging Label**Tagging**

CE SPERIAN

2091911 XX
EN 60903-2003
CEI 903-2002

Certifications

 **E.C. Declaration of Conformity**

EC Category PPE

3

Quality Assurance

ISO 9001 / 2000

EC Attestation

 EC Attestation

EC Attestation Number

0077/016/078/02/98/0001 - EXT 04/09/06

Photos & Images

We're sorry, there are no images available at this time.

Additional Information

User Information Sheet

106

Maintenance

Storage Information

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Store in original packaging (Opaque and anti-UV packaging used for protection and instructions for use). Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

Inspection : Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity.

Care Instructions

This article can be washed with soap and water at a temperature not exceeding 65°C.
The gloves must be dried throughly at a temperature not exceeding 65°C.

The Honeywell logo, consisting of the word "Honeywell" in a bold, red, sans-serif font.

[View other region sites](#)
© 2011 Honeywell International Inc.



SPERIAN PROTECTION GLOVES AUTUN
25, Porte d' Autun
St Forgeot
71400 AUTUN

En exécution de la directive 89/686/CEE du 21 décembre 1989 concernant le rapprochement des législations des états membres relatives aux équipements de protection individuelle et des décrets n° 92-765, 766 et 768 du 29 juillet 1992 portant transposition de cette directive en droit français,

Nom de l'organisme habilité : A.P.A.V.E. Parisienne

Adresse : 13/17 rue Salneuve - 75854 Paris Cedex 17

habilité par arrêté du ministère du travail, de l'emploi et de la formation professionnelle en date du 11 août 1992, identifié sous le numéro 0077,

attribue :

L' EXTENSION D' ATTESTATION D' EXAMEN CE DE TYPE

N° 0077/016/078/02/98/0001 - EXT 04/09/06

au modèle d'équipement de protection individuelle suivant :

- gants isolants pour travaux sous tension
- Electrosoft réf 20 919 11 - Classe 1 - Catégories R.C.
- Fabricant : SPERIAN PROTECTION GLOVES AUTUN, 25 Porte d'Autun, St Forgeot - 71400 Autun
- Responsable de la mise sur le marché : SPERIAN PROTECTION GLOVES AUTUN, 25 Porte d'Autun, St Forgeot - 71400 AUTUN
- Gants en latex naturel, de couleur beige, longueur 410 mm, manchette non contournée,
- Essais effectués suivant NF EN 60-903 - 2003, catégories RC.
- Objet de l'extension : mise en conformité avec la norme NF EN 60-903 - 2003, couleur beige, longueur 410 mm.

Cette modification ne remet pas en cause la conformité aux exigences essentielles qui ont été prises en compte pour l'attestation CE de type délivrée au modèle de référence.

Saint-Ouen, le 26 Mars 2008

L' Ingénieur Responsable
de l'Unité d'Evaluation E.P.I.

G. BLIN

Nota : Toute modification apportée au matériel neuf objet de la présente extension d'attestation d'examen CE de type doit-être portée à la connaissance de l'organisme habilité en application de l'article R 233-62 du Code du travail, ainsi que toute modification des informations contenues dans le dossier technique sur la base duquel l'extension d'attestation d'examen CE de type a été délivrée (changement de lieu, changement de raison sociale du fabricant, extrait de certificat d'assurance qualité,...)

Cette attestation comporte 5 pages numérotées 1/5, 2/5, 3/5, 4/5, 5/5.



E.C. Declaration of Conformity

The manufacturer or its legal representative supplier in the European Community:
Honeywell Safety Europe

Declares that the Personal Protective Equipment described here after conforms to the provisions of the European Council Directive 89/686/CEE:

Designation: ELECTROSOFT CLASS 1

Reference: 2091911

Standard(s): EN 60903

This PPE is the object of the below EC examination certificate n°:


Delivered by:

CENTRE TECHNIQUE DU CUIR
4 rue Hermann Frenkel
69367
Lyon Cedex 07

Drawn up in Roissy, on the 29/03/2013

By: Eric Puille

Division: Gloves



ZI Paris Nord II 33, rue des Vanesses BP 50288 95958 Roissy CDG France
Tel: +33 (0) 49 90 79 79 Fax: +33 (0)1 49 90 79 80

www.honeywellsafety.com