



PRODUCT NUMBER: 2092014

ELECTROSOFT COMPOSITE

Class 0

For electrical work with a maximum voltage of 1000 volts. Can be used without leather glove.

Overview	<p>Reference Number 2092014</p> <p>Product Type Gloves</p> <p>Range Electrical Protection</p> <p>Line Composite</p> <p>Brand Sperian</p> <p>Brand formerly known as ELECTROSOFT</p> <p>Industry</p> <ul style="list-style-type: none">Administration <p>Product Use For electrical work with a maximum voltage of 1000 volts. Can be used without leather glove.</p>
----------	--

Features & Benefits**Feature**

Insulating glove for electrical work
 External layer in orange polychloroprene
 Chlorinated inside
 Category RC, with mechanical protection

Benefit**COMFORT**

Its dielectric natural latex composition on chlorinated interior base makes it very comfortable.
 Product appreciated for its long life and precision.
 Its patterned finish gives it a highly appreciated grip in damp conditions.

RESISTANCE

The outer orange elastomer layer provides excellent mechanical resistance.
 Its anatomical shape makes flexing easier while ensuring a high level of protection.

SAFETY

It can be used without a leather overglove as it has been combined with a mechanically more resistant elastomer.

Technical Description**Description**

CE CATEGORY : III Irreversible risks
 In accordance with standards :
 EN 60903-2003
 CEI 903-2002

CHARACTERISTICS :

Insulating glove for electrical work
 External layer in orange polychloroprene
 Chlorinated inside
 Category RC, with mechanical protection

Product Technology

Dipped Gloves

Glove/liner color

Orange

Coating Type

Latex and polychloroprene

Length

36 cm

Thickness

2 mm

Harmlessness

In conformity with European standards

Dexterity

Class 0

Sizes


8 to 11

Packaging Label

Tagging

CE SPERIAN
2092014 XX
EN 60903-2003
CEI 903-2002


Certifications

 **E.C. Declaration of Conformity**

EC Category PPE

3

EC Attestation

 EC Attestation

EC Attestation Number

0077/016/078/06/06/0001 EXT 01/05/08

Photos & Images

We're sorry, there are no images available at this time.

Additional Information

User Manual

UI 106

User Information Sheet

106

Maintenance

Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 months.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

Care Instructions

Inspection : Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : use water and soap. Dry below 65°C with ambient humidity.

The Honeywell logo is displayed in a bold, red, sans-serif font.

[View other region sites](#)

© 2011 Honeywell International Inc.